

BIG SKY COUNTY WATER & SEWER DISTRICT NO. 363 SPANISH PEAKS SEWER CONNECTION PERMIT

| ITEMS TO BE SUBMITTED WITH THIS APPLICATION | APPLICATION DATE |
|--|--|
| <input type="checkbox"/> ARCHITECTURAL COMMITTEE APPROVAL WHERE APPLICABLE <input type="checkbox"/> ONE SET OF BUILDING PLANS W/ SITE PLAN - NO LARGER THAN 11" x 17" | <input type="checkbox"/> PLANS MUST SHOW SQUARE FOOTAGES FOR ALL SPACES <input type="checkbox"/> OTHER- _____ |

PART A (COMPLETED BY APPLICANT) OWNER AND PROPERTY INFORMATION

| | | | | | |
|--|----------------------------|---------------------------------------|--|---|------|
| NAME | | | | PHONE (W) | |
| MAILING ADDRESS | | CITY | STATE | ZIP CODE | |
| (H) | | | | | |
| COUNTY ASSIGNED PROPERTY ADDRESS | | | | | |
| LEGAL DESC. | SECTION - TOWNSHIP - RANGE | SUBDIVISION | LOT # | BLOCK # | COS# |
| | | | TRACT # | COUNTY | |
| | | | <input type="checkbox"/> GALLATIN <input type="checkbox"/> MADISON | | |
| BUILDING CONTRACTOR'S NAME & TELEPHONE # | | SEWER CONTRACTOR'S NAME & TELEPHONE # | | WATER SERVICE CONTRACTOR'S NAME (PLUMBER) & PHONE # | |

| | | |
|---|---|--|
| Tax Parcel ID# _____ <input type="checkbox"/> Single Family Residential <input type="checkbox"/> Apartment <input type="checkbox"/> Condominium <input type="checkbox"/> Commercial Total Sq. Ft. > _____ | <input type="checkbox"/> New Construction <input type="checkbox"/> Remodeling <input type="checkbox"/> Other: _____ | Architectural Committee Approval Date: _____ [IF APPLICABLE] State of Montana Approval Date: _____ [IF APPLICABLE] Estimated: Start Date: _____ Completion Date: _____ |
|---|---|--|

The above statements are true to the best of my knowledge. I hereby agree to pay all applicable impact, surcharge, and connection inspection charges indicated within SIXTY (60) days notice of permit application approval; and to comply with the provisions of the sewer connection permit when issued. All changes during construction, or future remodeling that increase the SFEs must be submitted to the District. I agree to provide ingress and egress to inspect or repair sewer main lines, stubs, services, and water meter equipment; and to verify SFE's. I also agree to comply with the construction methods required by the District for sewer service connections, and to give the District a minimum of **two days notice** for inspection of sewer service connection, prior to backfilling, and to allow a final inspection to verify the SFEs when the project is 100% complete. I acknowledge that I have read the permit conditions on the back of this application and agree to provide a copy of the conditions to the contractor(s) responsible for the sewer service installations. Noncompliance may result in revocation of this connection permit.

[PLEASE READ OTHER SIDE FOR PERMIT CONDITIONS]

| | | | |
|--------------------------|--------|---|------------|
| Signature of Owner _____ | [OR] | Signature of Authorized Agent for Owner _____ | Date _____ |
|--------------------------|--------|---|------------|

PARTS B,C & D COMPLETED BY DISTRICT PERSONNEL

PART B SINGLE FAMILY EQUIVALENT (SFE) CALCULATION

| | | |
|---|--|---|
| Connecting to: <input type="checkbox"/> Sewer Only | | TOTAL SFE's |
| Single Family Home or Single Condominium Home: | | |
| <input type="checkbox"/> < 2,000 Sq. Ft. 0.85 SFEs/1,000 Sq. Ft. | <input type="checkbox"/> 2,001 to 3,000 Sq. Ft. 0.65 SFEs/1,000 Sq. Ft. | |
| <input type="checkbox"/> 3,001 to 4,000 Sq. Ft. 0.55 SFEs/1,000 Sq. Ft. | <input type="checkbox"/> > 4,000 Sq. Ft. 0.45 SFEs/1,000 Sq. Ft. | |
| Total Square Feet: _____ x _____ /1,000 Sq. Ft. | | _____ |
| Each jacuzzi or hot tub draining to sewer system (# of Hot tubs): _____ x 0.35 | | _____ |
| Condominium developments (<input type="checkbox"/> SEE WORKSHEET): | | _____ |
| Commercial developments (<input type="checkbox"/> SEE WORKSHEET): | | _____ |
| Other: _____ | | _____ |
| PLANS REVIEWED BY: _____ DATE: _____ | | TOTAL SFE's FOR PROPERTY = _____ |

PART C PLANT INVESTMENT CHARGE - CONNECTION - METER FEE CALCULATIONS

| C.1 Sewer Plant Investment Charges: Sewer Plant Investment Charge: \$2,360 x # _____ SFE's = \$ _____ TOTAL PIC = \$ _____ | C.3 Metering Equipment Charges: Meter Size: _____ Inches # Meters: _____ @ \$ _____ Each Meter Horn: _____ Inches # Horns: _____ @ \$ _____ Each # MXUs: _____ @ \$ _____ Each <input type="checkbox"/> TBD # Fittings: _____ @ \$ _____ Other: _____ @ \$ _____ TOTAL METER = \$ _____ | | | | | | | | | | | | | | | | | | | | | |
|--|---|----------|-------|--|-------|----------|--|-----|----------|--|-----|----------|--|-----|----------|--|-------|----------|---|-----|----------|---|
| C.2 Connection/Inspection Fee (per connection): <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">SEWER</th> <th style="text-align: center;">TOTAL</th> </tr> </thead> <tbody> <tr> <td><input type="checkbox"/> Remodeling (If SFEs increase)</td> <td style="text-align: center;">\$ 50</td> <td style="text-align: center;">\$ _____</td> </tr> <tr> <td><input type="checkbox"/> Single Family Residence</td> <td style="text-align: center;">200</td> <td style="text-align: center;">\$ _____</td> </tr> <tr> <td><input type="checkbox"/> Duplex to Four-Plex</td> <td style="text-align: center;">350</td> <td style="text-align: center;">\$ _____</td> </tr> <tr> <td><input type="checkbox"/> 5-10 Units of Improvement and Commercial < 10,000 sq. ft.</td> <td style="text-align: center;">500</td> <td style="text-align: center;">\$ _____</td> </tr> <tr> <td><input type="checkbox"/> 11 or more units of improvement and Commercial > 10,000 sq. ft.</td> <td style="text-align: center;">1,250</td> <td style="text-align: center;">\$ _____</td> </tr> <tr> <td><input type="checkbox"/> Water Meter Installation Fee</td> <td style="text-align: center;">100</td> <td style="text-align: center;">\$ _____</td> </tr> </tbody> </table> | | SEWER | TOTAL | <input type="checkbox"/> Remodeling (If SFEs increase) | \$ 50 | \$ _____ | <input type="checkbox"/> Single Family Residence | 200 | \$ _____ | <input type="checkbox"/> Duplex to Four-Plex | 350 | \$ _____ | <input type="checkbox"/> 5-10 Units of Improvement and Commercial < 10,000 sq. ft. | 500 | \$ _____ | <input type="checkbox"/> 11 or more units of improvement and Commercial > 10,000 sq. ft. | 1,250 | \$ _____ | <input type="checkbox"/> Water Meter Installation Fee | 100 | \$ _____ | TOTAL PERMIT FEES (Total of C.1 + C.2 + C.3) TOTAL PLANT INVESTMENT CHARGE = \$ _____ TOTAL CONNECTION/INSPECTION FEE = \$ _____ TOTAL METER EQUIPMENT CHARGE = \$ _____ TOTAL FEES = \$ _____ |
| | SEWER | TOTAL | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Remodeling (If SFEs increase) | \$ 50 | \$ _____ | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Single Family Residence | 200 | \$ _____ | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Duplex to Four-Plex | 350 | \$ _____ | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> 5-10 Units of Improvement and Commercial < 10,000 sq. ft. | 500 | \$ _____ | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> 11 or more units of improvement and Commercial > 10,000 sq. ft. | 1,250 | \$ _____ | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Water Meter Installation Fee | 100 | \$ _____ | | | | | | | | | | | | | | | | | | | | |

[APPLICATION VOID IF FEES ARE NOT PAID WITHIN 60 DAYS OF NOTICE]

PART D APPLICATION SUMMARY

| | |
|--|---|
| FEES PAID: \$ _____ CHECK #: _____ DATE PAID: _____ PERMIT DATE: _____ EXPIRATION DATE: _____ | Applications exceeding 25.0 SFEs require Board approval. DATE BOARD APPROVED: _____ DATE BOARD DENIED: _____ |
| SIGNATURE OF DISTRICT REPRESENTATIVE _____ DATE _____ | |

This Sewer Connection Inspection Permit is issued subject to the following conditions:

1. A Sewer Connection Inspection Permit must be obtained from the District before any connection is made to the District's sewer collection system. **AN APPROVED SEWER CONNECTION INSPECTION PERMIT MUST BE MADE AVAILABLE AT THE JOB SITE UPON REQUEST** (Section 304, WSD363 Ordinance 97-1001).
2. The owner is responsible for the cost of the sewer service from the building drain to the lateral stub at the property line (WSD363 Ordinances 97-1001 and 99-1002).
3. All sewer lateral stubs shall be located by District personnel with the best information available. The owner or their contractor is responsible for finding the sewer lateral stub.
4. All connections to the District's public sewer system shall be to the sewer lateral stub at the lot line. If a sewer lateral stub has not been stubbed to the lot line, then the **Owner** will be responsible for the cost of installing a lateral from the main line to the property line..
5. Before installing a sewer, the contractor should inspect the existing sewer lateral stub at the property line (if one exists) to determine if there is enough pitch from the structure to the sewer connection.
6. The contractor is responsible for maintaining all service line set back requirements to structures, lot lines, private wells, etc. Where applicable, the contractor and home owner are responsible for any variances needed to install the sewer service line.
7. All sewer laterals must be constructed and laid in accordance with the Montana Public Works Standard Specifications, or any other applicable regulations of the District including but not limited to the following specifications:
 - a. **Pipe Bedding**- 4 inches under lateral and 6 inches over lateral piping, using 1 inch minus **washed** bedding material is required (Section 02221 and Standard Drawing 02724-1).
 - b. **Minimum Slope**- All sewer laterals must be installed at a minimum slope of 2.00% (14" PER FOOT) (Standard Drawing 02724-1).
 - c. **Clean Outs**- One **DOUBLE SWEEP TEE** is required within 10 feet from the building, and a double sweep tee every 100 feet thereafter (Section 406 and 1107, Uniform Plumbing Code), and a double sweep tee shall also be installed at the lot or easement line.
 - d. **Locate Wire**- All sewer laterals must be installed with locate wire, #10 AWG insulated.
 - e. **Materials**- All SEWER LATERAL pipe shall be schedule **40 PVC**. No thin wall pipe (including schedule 35 PVC) is permitted.
 - f. **Accessibility**- All CLEANOUTS will be readily accessible at the completion of the project.
 - g. **Pumped Services**- Spanish Peaks has lots that will require a pumped sewer service. Contact the District for information for connections that will require a pumped service connection.
8. All septic tanks, holding tanks, and dry wells must be pumped out and abandoned in accordance with all state and local regulations.
9. All sewer laterals must be inspected, tested and approved by a representative from the District prior to backfilling over the sewer service.
10. The sewer lateral contractor must have the site prepared safe for inspection and must give the District at least **ONE (1)** business day advance notice when the laterals are ready for inspection and connection to the public sewer system.
11. In areas where groundwater conditions necessitate dewatering, the sewer lateral contractor shall use appropriate dewatering equipment and comply with all local and state regulations. The sewer lateral contractor shall **not** use any part of the District's sewer collection system for trench dewatering.
12. The sewer lateral contractor is responsible for the removal of any mud, sand, or other debris which enters the sewer system as a result of the lateral installation procedure.
13. The sewer lateral contractor is responsible for any damages, or disturbance to the public right-of-way and roads. Restoration of the public right-of-way and/or roads will be the responsibility of the sewer lateral contractor. The restoration work must be completed in a manner that is satisfactory to the District (Section 608, WSD363 Ordinance 97-1001).
14. Sewer Connection Permits are generally valid for a period of **ONE YEAR** for most projects from the date of issuance. The sewer laterals must be installed and inspected within the term of the permit, if they are not, the owner may file for a permit extension. If construction has not commenced within one year from the date of permit issuance, the permit will become null and void.
15. Sewer laterals and water service laterals shall not be laid in a common trench. At least 10 feet of separation must be maintained without prior approval of the District. If sewer & water lines cross, at least 18 inches of separation must be maintained.
16. See District website **WWW.BIGSKYWATERSEWER.COM** for more information about the District's Standard Specifications and Requirements