



| HORIZONTAL LAYER INSULATION | | | INVERTED U-INSULATION | | |
|-----------------------------------|----------------------|------------------|-----------------------------------|----------------------|--|
| DEPTH OF BACKFILL OVER INSULATION | INSULATION THICKNESS | INSULATION WIDTH | DEPTH OF BACKFILL OVER INSULATION | INSULATION THICKNESS | $2B + A \geq$ WIDTH OF HORIZONTAL LAYER INSULATION |
| | | | | | $2B + A$ |
| 2'-0" | 3.0" | 5'-6" | 2'-0" | 3.0" | $> 5'-6"$ |
| 3'-0" | 2.5" | 5'-1" | 3'-0" | 2.5" | $> 5'-1"$ |
| 4'-0" | 2.0" | 3'-1" | 4'-0" | 2.0" | $> 3'-1"$ |
| 5'-0" | 1.5" | 1'-1" | 5'-0" | 1.5" | $> 1'-1"$ |
| 6'-0" | 1.0" | 1'-0" | 6'-0" | 1.0" | $> 1'-0"$ |
| 7'-0"* | 1.0" | 1'-0" | 7'-0" | 1.0" | $> 1'-0"$ |

- NOTES:
 1. INSULATE UNDER PAVING, SIDEWALK AND DRIVEWAYS.
 2. ALL PARTS MUST BE APPROVED BY BSWSD 363.

| | | | | |
|---|---|----------------|---|--------------------------------|
| DETAIL NO.: BSWSD: 26-18 | BIG SKY WSD 363 STANDARD DRAWING | SCALE: NONE | BURIED WATER SERVICE LINE INSULATION | DATE: FEBRUARY 2010 |
| | | | | LAST REVISION: MAY 11, 2010 |
| | | | | CROSS REFERENCE WITH: N/A |
| | | | | |